



# Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller


Fenster • windows  
Rollläden • shutters  
Türen + Tore • doors  
Fassaden • curtain walling  
Baubeschläge • building hardware

**TEST CERTIFICATE NO. 220-01-0713-Z1**

Version 1.en

Initial type testing (ITT) of performance characteristics in accordance with EN 14351-1 :2006 + A2 : 2016 “Windows and doors - Product standard, performance characteristics - Part 1: Windows and external pedestrian doorsets– German version EN 14351-1:2006 + A2:2016”

**Applicant** Deceuninck TR  
MPIO SB Atatürk Plastik OSB Mah. 5.Cad. No:4  
Menemen - İzmir  
Türkiye



**Product type** Sliding single sash door with fixed glazing side part, Aluminum, double glazing

**Product name** IQ Aluminum System - IQ-1350 Ingentis

**Hardware** Siegenia Aubi

**Sealing** EPDM and Brush sealing


**Dimension** Total outside dimensions (W x H) max. 2200 mm x 2200 mm

**Classification** According to test report No. 220-01-0713-B1 from November 11, 2020:



EN 1026	Air Permeability	EN 12207	Class 4
EN 1027	Water tightness	EN 12208	Class E750
EN 12211	Resistance to wind load	EN 12210	Class C4/B5

**Validity** Period of validity of EN 14351-1 : 2006 + A2 : 2016

  
Nedret Sürmeli  
Head of Test Laboratory Branch  
Office PFB Turkey  
PFB Prüfzentrum für Bauelemente  
Yapı Elemanları Test Merkezi San.  
Ve Tic. Ltd. Şti.



  
Yiğit Altuğ  
Responsible Official