

# Evidence of Performance

Resistance to wind load  
Watertightness  
Air permeability

Test report 102 43902/1e



Client **EGE PROFİL TİC. VE SAN. A.Ş. ( IQ ALUMINIUM SYSTEMS)**  
**10006 SOK. NO : 4 A.O.S.B**  
**ÇİĞLI-İZMİR**

Product **Tilt and turn window with fixed sublight**  
System **FORMO W55 1,6 Yalitimli Dograma Sistem**  
Overall dimensions (WxH) **1,100 mm x 2,100 mm**  
Frame material **Aluminium profiles with thermal break**  
Special features **-/-**

## Basis

EN 14351-1 : 2006-03

Test standards:

EN 1026 : 2000-06

EN 1027 : 2000-06

EN 12211 : 2000-06

EN 12046-1 : 2003-11

EN 14609 : 2004-03

Corresponds to the national standard. (DIN EN)

## Representation



## Instruction for use

The present test report serves to demonstrate the above characteristics of windows according to EN 14351-1:2006-03. The results obtained can be used by the manufacturer as the basis for the manufacturer ITT test report summary. The conditions and requirements set out by EN 14351-1:2006-03 shall be observed.

## Validity

The data and results refer solely to the tested and described specimen.

The test results can be extrapolated as per EN 14351-1, under observance of Annex E 1., under the manufacturer's own responsibility.

The test does not allow any statement to be made on further characteristics of the present structure and quality, in particular the effects of weathering and ageing.

## Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

The cover sheet can be used as an abstract.

## Contents

The report contains a total of 14 pages.

Notified Body Nr 0757  
Anerkannte PUZ-Stelle BAY 18



## Resistance to wind load – EN 12210



**Class C3 / B3**

## Watertightness – EN 12208



**Class E900**

## Air permeability – EN 12207



**Class 4**

ift Rosenheim  
21. Juni 2010

Jörn Peter Lass, Dipl.-Ing. (FH)  
Head of Testing Department  
ift Centre Windows & Facades



ift Rosenheim GmbH

Geschäftsführer  
Dipl.-Ing. (FH) Ulrich Sieberath  
Dr. Jochen Peichl

Robert Kolacny, Dipl.-Ing. (FH)  
Test engineer  
ift Centre Windows & Facades

Theodor-Gietl-Str 7 - 9  
D-83026 Rosenheim  
Tel. +49 (0)8031/261-0  
Fax +49 (0)8031/261-290  
www.ift-rosenheim.de

Sitz 83026 Rosenheim  
AG Traunstein HRB 14763  
Sparkasse Rosenheim  
Kto 3822  
BLZ 711 500 00