



Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller


Fenster • windows
Rollläden • shutters
Türen + Tore • doors
Fassaden • curtain walling
Baubeschläge • building hardware

TEST CERTIFICATE NO. 2021-27-0224-Z1

Version 1.en

Initial type testing (ITT) of performance characteristics in accordance with EN 14351-1 :2006 + A2 : 2016 “Windows and doors - Product standard, performance characteristics - Part 1: Windows and external pedestrian doorsets– German version EN 14351-1:2006 + A2:2016”

Applicant Deceuninck TR
MPIO SB Atatürk Plastik OSB Mah. 5.Cad. No:4
Menemen - İzmir
Türkiye



Product type Sliding single sash door with fixed glazing side part, Aluminum, double glazing

Product name IQ Aluminum System - Serenad

Hardware Deceuninck

Sealing EPDM and Brush sealing

Dimension Total outside dimensions (W x H) max. 2200 mm x 2200 mm

Classification According to test report No. 2021-27-0224-B1 from March 11, 2021:



EN 1026	Air Permeability	EN 12207	Class 4
EN 1027	Water tightness	EN 12208	Class E900
EN 12211	Resistance to wind load	EN 12210	Class C2/B3

Validity Period of validity of EN 14351-1 : 2006 + A2 : 2016

Nedret Sürmeli
Head of Test Laboratory Branch
Office PFB Turkey
PFB Prüfzentrum für Bauelemente
Yapı Elemanları Test Merkezi San.
Ve Tic. Ltd. Şti.



Yiğit Altuğ
Responsible Official