



Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller

Fenster · windows
 Rollläden · shutters
 Türen + Tore · doors
 Fassaden · curtain walling
 Baubeschläge · building hardware


TEST CERTIFICATE NO. 19/10-A007-Z1

Version 1.en

PfB-Internal-No. 2019-27-0826

Initial type testing (ITT) of performance characteristics in accordance with EN 14351-1 :2006 + A2 : 2016 "Windows and doors - Product standard, performance characteristics - Part 1: Windows and external pedestrian doorsets- German version EN 14351-1:2006 + A2:2016"

Applicant Deceuninck TR - Ege Profil Tic. ve San.A.Ş.
 MPIO SB Atatürk Plastik OSB Mah. 5.Cad. No:4
 Menemen - İzmir
 Türkiye



Product type Tilt and turn single casement window with fixed bottom part, Aluminum, double glazing





Product name IQ Aluminum System - Oval

Hardware Giesse


Sealing EPDM

Dimension Total outside dimensions (W x H) max. 1250 mm x 2100 mm

Classification According to test report No. 19/10-A007-B1 from November 25, 2019:

	EN 1026	Air Permeability	EN 12207	Class 4
	EN 1027	Water tightness	EN 12208	Class E1050
	EN 12211	Resistance to wind load	EN 12210	Class C5/B5
	EN 12046-1	Operating Forces	EN 13115	Class 1

Validity Period of validity of EN 14351-1 : 2006 + A2 : 2016


 Dipl. Ing. (FH) Rüdiger Müller
 Head of Institute




 Yiğit Altuğ
 Responsible Official