



Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller

Fenster · windows
 Rollläden · shutters
 Türen + Tore · doors
 Fassaden · curtain walling
 Baubeschläge · building hardware

TEST CERTIFICATE NO. 17/11-A005-Z1

Version 1.en

PfB-Internal-No. 18/01-A021

Initial type testing (ITT) of performance characteristics in accordance with EN 14351-1 :2006 + A1 : 2010 “Windows and doors - Product standard, performance characteristics - Part 1: Windows and external pedestrian doorsets without resistance to fire and/or smoke leakage characteristics – German version EN 14351-1:2006 + A2:2016”

Applicant IQ Aluminium Systems -Ege Profil Tic. ve San.A.Ş.
 Atatürk Plastik OSB Mah.5 Cad.4
 Menemen / İzmir
 Turkey

Product type Single casement sliding door with fixed side part
 AL, double glazing

Product name Renovatio Series

Hardware Sigenia-Aubi


Sealing EPDM

Dimension Total outside dimensions (W x H) max. 2200 mm x 2200 mm


Classification According to test report No. 17/11-A005-B1 of January 17, 2018:



EN 1026	Air Permeability	EN 12207	Class 4
EN 1027	Water tightness	EN 12208	Class E1050
EN 12211	Resistance to wind load	EN 12210	Class C5/B5



Validity Period of validity of EN 14351-1 : 2006 + A2 : 2016


 Dipl. Ing. (FH) Rüdiger Müller
 Head of Institute




 Yiğit Altuğ
 Responsible Official